

Joy, IL December 2022 Council Report

Water System

We had an issue with the softeners not regenerating a few weeks ago. We noticed that we had no power at the softener panel. I called Britton Electronics as they do all the SCADA and automation work for Aledo and the other Illinois towns that I work with. They came over and tested everything and determined that the power supply was bad. They rigged up a temporary solution by directly wiring the softener panel to the main panel with an old extension cord that we clipped the ends off. They are ordering a new power supply.

We had a water main break on Sunday. It was repaired on Monday. We did get a little low in the tower but managed to stay above 20 psi. At the same time, we were dealing with the main break, the fire department was filling their trucks to deal with a fire, so that did not help in terms of recovering our storage. I spoke with Aledo, and they allowed the fire department to use one of their hydrants so we wouldn't have that continued demand.

Wastewater System

Nothing of note for the wastewater system currently.

Chad McCleary
Ion Environmental Solutions