

Joy, IL April 2023 Council Report

Water System

Everything went fine with the Well 2 reinstall. We did the chemical treatment and ran it to water plant so it ran through the raw water main. We have since passed two separate rounds of sampling. With that, we are considering everything to be a success with regards to finally dealing with the bacteria problem.

That said, we have been unable to run Well 2 remotely from the water plant. We have gone through every setting we can find and have not been able to get it to run in automatic. I put in a call to Britton Electronics to stop by and look at it when they come to Aledo in the next few weeks.

Otherwise, things are running fine at the water plant.

I submitted the updated service line inventory to the EPA.

I am working on the CCR for 2022.

Wastewater System

Nothing of note for the wastewater system currently.

Chad McCleary
Ion Environmental Solutions