

## Joy, IL January 2024 Council Report

### Water System

The transducer issue with the brine tank is fixed. We were able to cut into the line and found that it was just full crud. We got it cleaned and replumbed with a union so in the future, it will be really easy to clean if this happens again.

Obviously, the weather has been a big deal, and we've had some concerned about freezing and possible main breaks. So far, we've managed to dodge all that, but we have a few more days to go before it warms up so we'll make sure to be on top of anything that pops up.

We have a nitrate sample due this quarter.

### Wastewater System

Nothing of note for the wastewater system.

Chad McCleary  
Ion Environmental Solutions