

Joy Council Report – June 2026

Water System

I received a billing report from Gwen, and after review, we do not show significant water loss. Flows have been higher, but this is because water is being billed at a higher rate. Gwen and I are going to review some additional data, but I'm less suspicious of a leak since water billed/consumed is higher than it has been historically.

The drive on the VFD for well two needs to be replaced. Britton is putting a quote together for that plus the transducer I previously reported on.

Wastewater System

All samples were in compliance for May. With the heavy rain this last week, our flows have been high again.

Chad McCleary

Ion Environmental Solutions