

Joy Council Report – July 2026

Water System

We are waiting on Britton to get all the parts for the VFD. As soon as they have these in house they will make the repairs.

Wastewater System

Electric Pump came to do their annual maintenance at the lift station. They ended up taking pump #2 to their shop because of a seal failure.

All samples were in compliance for June. With the heavy rain throughout the month, we did have high flows several days.

Chad McCleary

Ion Environmental Solutions